

Interfuels: PEV (Plug-in Electric Vehicle) Charging Infrastructure

Jim Francfort
Washington, D.C.
June 2016



www.inl.gov

This presentation does not contain any proprietary, confidential, or otherwise restricted information

INL/MIS-16-38965

Vehicle / Infrastructure Testing Experience

- **Since 1994, INL has benchmarked PEVs and electric vehicle supply equipment (EVSE) with telematics systems in the field, and on closed test tracks and dynamometers**
 - **250 million test miles of data from 27,000 electric drive vehicles and 16,600 charging units**
 - **EV Project: 8,228 Leafs, Volts and Smarts, 12,363 EVSE and DCFC**
 - **4.2 million charge events, 124 million test miles. At one point, 1 million test miles every 5 days**
- **PEVs include both electric (EV) and plug-in hybrid electric (PHEV) vehicles**

AC EVSE Definition

- **AC Level 1 and 2 electric vehicle supply equipment (EVSE)**
 - EVSE is a piece of equipment that allows a PEV to be safely connected to the grid via SAE J1772 connector
 - EVSE are not chargers
 - Bridges the PEV and electric grid gap
 - Provides electricity to the PEV's on-board power electronics and on-board charger
 - Suited for fleets, public access and residential locations



DCFC Definition

- **Direct Current Fast Charger (DCFC)**
 - It is a charger that sits off-board the vehicle and it converts AC grid energy to DC vehicle energy
 - Larger and more expansive than AC Level 1 and 2 EVSE, but it charges a PEV much faster
 - Provides electricity directly to the vehicle's battery
 - Requires sophisticated DCFC-to-PEV communication
 - Suited for fleets and public access



Charging Infrastructure Definitions

- **AC EVSE (on-board vehicle charger)**
 - AC Level 1: 120V AC (up to 16 Amps, 1.92 kW Max)
 - AC Level 2: 240V AC (up to 80 Amps, 19.2 kW Max)
 - AC Level 3: > 20kW
 - Most PEVs have onboard chargers that operate at 3.3 or 6.6 kW, however one charges at 10 kW
- **DCFC Charging (uses off-board vehicle charger)**
 - DC Level 1: Up to 20 kW
 - DC Level 2: Up to 90kW (DCFC most frequently in use today)
 - DC Level 3: >80kW (proposed)

AC Level 1 Charging Level

- **Hardwired or portable when plugged into 110/120 V electric outlets, safely connects the PEV to the grid**
- **Charge Times (general approximation)**
 - **BEV: 14 hours (20 kWh battery) to 39 hours (56 kWh battery)**
 - **PHEV: 2 to 13 hours (depends on battery size)**
- **The portable cord set that must utilize a UL approved SAE J1772 vehicle connector, GFCI, and otherwise meet NEC 625 requirements**



AC Level 2 Charging Level

- Most common public EVSE type used for PEV charging
- Charge times (general approximation)
 - 20 kWh BEV battery 3 hours (at 6.6 kW) to 56 kWh battery in 8.5 hours (at 6.6k kW)
 - PHEV 1 to 6 hours (at 3.3 kW)
- **Better suited than Level 1 for charging today's larger battery packs and the future's even larger battery packs**
- AC energy transferred to the onboard vehicle charger
- Permanently attached to a wall or pedestal, GFCI, some vehicle communication, UL approved, NEC 625 requirements and SAE standards, including J1772 connector:



DC Fast Charger (DCFC)

- **Three DCFC technologies exist**
 - Japanese CHAdeMO protocol connector
 - SAE standard connector (SSC)
 - Tesla DCFC
 - **The three are mostly not compatible**
 - Some DCFC have both CHAdeMO and SSC connectors
- **Charge Times are dependant on battery size**
 - 20 kWh BEV 50% recharge in at least 20 minutes and 80% recharge in 30-40 minutes (50 kW DCFC)
 - Charge times very dependent on charger / battery sizing, state of charge (SOC) and temperatures
 - Not used for PHEVs due to small relative battery sizes
 - Common use: fleets, intercity grid pattern, or travel routes between cities in commercial settings
 - Relative high cost, large volume and heavy weight




DCFC Capable Vehicles

- **DCFC Capable (all BEVs)**
 - **BMW i3 – CCS (SAE Combo Connector Standard)**
 - **Chevrolet Spark – CCS**
 - **Mitsubishi i-MiEV – CHAdeMO**
 - **Nissan Leaf – CHAdeMO**
 - **Kia Soul – CHAdeMO**
 - **Other OEMs may offer**
- **EVSE Level 2 Capable**
 - **All PEVs**
- **EVSE Level 1 Capable**
 - **All PEVs**




AC Level 1 & 2 EVSE Testing

- **99%+ efficiency**
- **AC energy consumption at rest and during Volt Charging benchmarked**



- **Most AC EVSE consume 13 W or less at rest**
- **Standby power use tied to features**
- **Most AC EVSE consume under 30 W during charge**






DCFC Testing

- **ABB DCFC (CHAdeMO option)**
 - 92.3% overall charge efficiency (480V to battery)
 - 49.7 AC kW peak grid power
 - 45.9 DC kW peak DC charge power to a 2015 Leaf
- **Hasetec DCFC (CHAdeMO)**
 - 88.7% Overall charge efficiency (480VAC to battery)
 - 53.1 AC kW peak grid power
 - 47.1 DC kW peak charge power to a 2011 Leaf



Time-of-Use (TOU) Charging

- TOU electricity rates and other considerations may require starting charging hours after connection times
- PEVs and smart EVSE have charge time controls
 - Charging start times can be controlled either way
- In the EV Projects' San Diego region, TOU was available with \$0.49/kWh peak and \$0.16/kWh super off-peak rates
 - Left graph shows connection times
 - Right graph shows charging start times






Time-of-Use (TOU) Charging

- **Delayed charging start times can be as simple as pushing a button 1, 2, 3, or 4 times**
- **Or, programing the vehicle or EVSE by drivers**



Wireless Power Transfer Brief Discussion

- INL has tested 4 systems to date




<http://avt.inel.gov/evse.shtml>

AC Level 2 EVSE Installation Costs

- Installation cost data for analysis is available for 2,479 units
- Average installation cost per EVSE, for publicly accessible Level 2 in the EV Project, was \$3,108
- The five most expensive geographic markets had per unit installation costs over \$4,000 (\$4,004 to \$4,588)
- The five least expensive geographic markets had per unit installation costs under \$2,600 (\$2,088 to \$2,609)
- Similar to residential EVSE and DCFC installation costs, AC Level 2 EVSE installed in California were the most expensive installations





Public AC Level 2 EVSE Installation Costs




AC Level 2 EVSE Installation Costs

- The highest installation costs due to
 - Distance between EVSE and power distribution panel
 - The nature of the surface needing restoration as a result of the EVSE installation
- Labor cost is primary geographic differentiator of EVSE installation cost
 - Labor costs can be mitigated by wall mount versus pedestal installation



AC Level 2 EVSE Installation Costs

- The distance and surface condition variations had more impact on installation cost than the number of units installed per site



AC Level 2 EVSE Installation Cost Drivers



Pedestal EVSE installed on **decorative paving**; **removal and replacement** required for underground conduit



Pedestal EVSE installed on concrete pad, with **underground boring** for conduit



Pedestal EVSE installed on asphalt, **with trenching and repaving** for underground conduit

Level 2 EVSE Installation Cost Savings



Wall-mounted EVSE installed in parking garage with overhead surface-mounted conduit



Wall-mounted EVSE installed on block divider wall with surface mounted conduit



Wall-mount EVSE installed on building pillar with backing plate and overhead surface mounting for conduit

Utility Demand Charges on AC Level 2 EVSE

- **Some electric utilities impose demand charges on the highest power delivered to a customer in a month**
- **Simultaneously charging plug-in electric vehicles via multiple AC Level 2 EVSE can create significant increases in power demand**
 - **4 EVSE x 6.6 kW = 26.4 kW**
- **Many utilities start demand charges at 20 kW**
- **Demand charge can exceed \$1,000 per month**
- **The increased charging rate allowed by many newer plug-in-electric vehicles (PEVs) will exacerbate this impact**



DCFC Installation Costs for 111 Units

- **EV Project installed 111 DCFCs**
 - **Installation costs varied widely from \$8,500 to over \$50,000**
 - **Declined \$75,000 installation estimate**
- **The median cost to install the Blink dual-port DCFC in the EV Project was \$22,626. Does NOT include DCFC unit cost**
- **The addition of new electrical service at the site was the single largest differentiator of installation costs**
- **The surface on or under which the wiring and conduit were installed was second largest cost driver**
- **Cooperation from the electric utility and/or the local permitting authority is key to minimizing installation costs (both money and time) for DCFCs**
- **Presenter aware of:**
 - **British Columbia installation costs of \$100,000+ per site**
 - **New York City \$350,000 estimate for one installation: abandoned**
 - **Required approval from 29 departments/commissions**

Characteristics of Most Expensive DCFC Installations

- In some cases, the increased cost for new service was compounded by long underground conduits
- Another consideration for the DCFC site hosts is installation time:
 - Contractors installing equipment
 - Contractors waiting to start
 - Contractors waiting to finish
- When things went smoothly the installation took from 30 to 60 days from the agreement to proceed
- When there were delays in administration and materials the duration of the installation from start to finish often exceeded 90 days



Characteristics of Least Expensive DCFC Installations

- The very lowest cost installations (Sears) had sufficient power and a simple installation with either short underground conduit runs (i.e., hand-shoveled) or surface-mounted conduit
- Of the three installations that cost less than \$9,000, the sites had sufficient existing power at the site and they used surface-mounted electrical conduit



Installation Cost Drivers



Workplace AC EVSE Installation Cost Savings

- **Wall-Mounted Installations**
 - **Greater freedom as to the installation location at a site led to more wall-mounted installations**
 - **Wall-mounted EVSE were typically less expensive to install, because they did not require underground conduit to supply power, which is typical for a pedestal unit**
 - **The average cost to install a wall-mount AC Level 2 EVSE was \$2,035**
 - **The average cost to install a pedestal AC Level 2 was \$3,209**



Signage and To Bollard or Not?



Work Installation Considerations - Level 2 vs. DCFC

- Installing Level 2 EVSE cost on average 1/7th the cost of DCFC
- Level 2 hardware costs from ~\$500 to ~\$7,000
- DCFC hardware costs from \$20,000 to \$45,000
- Data collection and fees intended?
 - Annual back office and maintenance fee costs
 - Level 2 EVSE from \$0 to \$1,000 annually
 - DCFC about \$5,000 (assumes \$250 / month demand charge)




General Installation Considerations

- Establishing EV charging infrastructure has unique challenges in that drivers are not used to seeing electric vehicle supply equipment (EVSE) and may be unfamiliar with its purpose and use
- Without specific signage to the contrary, internal combustion engine vehicle drivers may park in spaces equipped with an EVSE because they are convenient and vacant



ADA Cost Driver Installation Costs

- Another factor that affected installation costs in different markets was implementation of Americans with Disability Act (ADA) requirements as understood by the local permitting authority having jurisdiction
 - In general, for every 25 parking spaces, one parking space should be accessible. For every six parking spaces that are accessible, one parking space should be van accessible



Workplace Cost Savings

- **Flexibility of workplace installations gives the ability to install EVSE with fewer accessibility requirements:**
 - Typically there were few, if any, parking signage or striping requirements
 - ADA accessibility, including an accessible pathway to the workplace building, was only necessary if an employee was a PEV driver and required this accessibility
 - EVSE did not need to be in conspicuous locations



Public AC EVSE and DCFC Site Considerations

- **Geographic Coverage / Planning**
- **Local attraction(s)**
- **Proper charger level for location**
- **ADA Requirements**
- **Lighting / Security**
- **Signage**
- **Access**
- **Local Permitting Authority**




Determining per Paycheck Fee for Workplace Employee Charging with No Data Collection

Distance in miles before charging per day * vehicle efficiency / 100 * local electricity price * ((pay periods per year * workdays per pay period) – holidays – vacation days – sick days – government shutdown days – travel days away from home office) / pay periods per year / 100

- **From the report: “PEV Workplace Charging Costs and Employee Use Fees” -**
<https://avt.inl.gov/sites/default/files/pdf/EVProj/PEVWorkspaceChargingCostsAndEmployeeUseFeesMarch2016.pdf>

Environmental and Speed Impacts on PEVs

- The range of all PEVs are impacted by:
 - Ambient temperatures,
 - Operating speed
- As an example: 2013 Ford Focus electric - dynamometer testing
 - UDDS at 72°F = 4.1 miles / kW
 - UDDS at 20°F = 1.7 miles / kW
- The below graphs document speed impacts on efficiency: 2013 Ford Focus electric - Steady-State Speed (dyno) impact on efficiency and range



Questions?

For publications and general PEV and charging infrastructure information, visit <http://avt.inl.gov>